


Tag Numbers
Thermowells:
7CAA-TW-7000
7CAA-TW-7601
7CAA-TW-7800
8CAA-TW-8601



JMS SOUTHEAST INCORPORATED CERTIFIES THIS DRAWING IS IN ACCORDANCE WITH JMS SOUTHEAST INCORPORATED ENGINEERING SPECIFICATIONS AND ACCURATELY REPRESENTS THE EQUIPMENT FURNISHED. THIS DRAWING IS THE SOLE PROPERTY OF JMS SE, AND MUST BE RETURNED UPON DEMAND. IT MAY NOT BE REPRODUCED NOR THE INFORMATION CONTAINED THEREIN USED WITHOUT THE WRITTEN PERMISSION OF JMS SOUTHEAST INCORPORATED

Company Name:
MEAD OBRIEN

Reference Data:	Drawing #: QD9212	Rev 0
-----------------	-----------------------------	--------------

Project Name: Fort St. Vrain	TOLERANCE TABLE: PROBE (L): 0-48" ±1/8" 48"-144" ±1/4" 144"+ -1"/+2" WIRE (L): <24" -1/2"/+1" >24" -1/2"/+2" PROT. TUBE (P&U): ±1/4" FRACTIONAL DIM: ±1/8" DECIMAL DIM: ±0.10" XXX ±0.010" XXXX ±0.005" UNLESS STATED OTHERWISE	JMS SOUTHEAST, INC. Temperature Measurement 105 Temperature Lane Statesville, North Carolina 28677 Phone: (704) 873-1835 Fax: (704) 878-6166 www.jms-se.com Email: sensors@jms-se.com
Generated By		
Date	Initials	

02/13/26

Thermowell					
Connection Type	Threaded; Plug/Chain: No			Material	316 SS
Shank Style	Tapered	Bore Dia. (d)	0.26"	Sensor Conn. (IC)	1/2" NPT
Stem Length (U)	8"	Lag Extension (T)	None	Process Conn. Size	3/4" NPT
Root (Q)	7/8"	Tip Thickness (t)	1/4"		
Tip OD (B)	5/8"	Step Length (Ls)	N/A		
Tagging	Stamped On Well (Std)				
JMS Part #	52TT2NU8ZK1				



Not to Scale