


| Sensor | |
|------------------|---|
| Sensor | RTD, 100 Ω, α=0.0385, ±0.15°C Accuracy at 0°C, 4 Wire, Dual Element, Max Temp: < 660°C (1220°F) |
| Construction | Standard Constr., Insul. MgO, 316 SS, 1/4" OD, 9" L, Normal, Closed Tip |
| Attaching Device | Double Threaded SS Spring-Loaded Fitting, 1/2" NPTM |
| Cold-End | Head: General Purpose, Aluminum, Screw Cap & Chain, NEMA 4, 1/2" x 3/4" Conduit Conn. |
| Tagging | Paper Tag; Options: Add JMS P/N |
| JMS Part # | 3EDBNK9"ESPZZWZM3 |

JMS SOUTHEAST INCORPORATED CERTIFIES THIS DRAWING IS IN ACCORDANCE WITH JMS SOUTHEAST INCORPORATED ENGINEERING SPECIFICATIONS AND ACCURATELY REPRESENTS THE EQUIPMENT FURNISHED. THIS DRAWING IS THE SOLE PROPERTY OF JMS SE, AND MUST BE RETURNED UPON DEMAND. IT MAY NOT BE REPRODUCED NOR THE INFORMATION CONTAINED THEREIN USED WITHOUT THE WRITTEN PERMISSION OF JMS SOUTHEAST INCORPORATED

| | | | | |
|--|--|---|-----------------------------|--------------|
| Company Name: KMW ENERGY GROUP | | Reference Data: | Drawing #: QD9710 | Rev 0 |
| Project Name: | TOLERANCE TABLE: PROBE (L): 0-48" ±1/8" 48"-144" ±1/4" 144" + -1"/+2" WIRE (L): <24" -12"/+1" >24" -12"/+2" PROT. TUBE (P&U): ±1/4" FRACTIONAL DIM: ±1/8" DECIMAL DIM: ±0.10" XXX ±0.010" XXXX ±0.005" UNLESS STATED OTHERWISE |  JMS SOUTHEAST, INC. Temperature Measurement 105 Temperature Lane Statesville, North Carolina 28677 Phone: (704) 873-1835 Fax: (704) 878-6166 www.jms-se.com Email: sensors@jms-se.com | | |
| Generated By | | | | |
| Not to Scale | | Rev. 10-01-2015 | | |