



FM Approvals  
1151 Boston Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

Member of the FM Global Group

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

**7080a-b-c. Series Junction Boxes.**

XP/II/1/BCD/Ta = -40°C to +85°C; DIP/II,III/1/EFG/Ta = -40°C to +85°C; Type 4X, IP66

a = Model AE, AM, SE, SM, TE, TM, WE or WM.

b = Entry configuration 00, 01, 02, 03 or 04.

c = Entry type 05, 07, 18 or 22.

**7080a-b-c. Series Junction Boxes.**

XP/II/1/BCD/Ta = -40°C to +85°C; DIP/II,III/1/EFG/Ta = -40°C to +85°C; IP66

a = Model CE, CM, NE or NM.

b = Entry configuration 00, 01, 02, 03 or 04.

c = Entry type 05, 07, 18 or 22.

**8066PB-a. Series Instrument Enclosures.**

XP/II/1/BCD/Ta = -40°C to +85°C; DIP/II,III/1/EFG/Ta = -40°C to +85°C; Type 4X, IP66

a = Entry configuration 04, 05, 06, 07, 08, 09, 13, 14, 17, 18, 19, 20, 21 or 22.

**8066PD-a. Series Instrument Enclosures.**

XP/II/1/BCD/Ta = -40°C to +85°C; DIP/II,III/1/EFG/Ta = -40°C to +85°C; Type 4X, IP66

a = Entry configuration 04, 05, 06, 07, 08, 09, 13, 14, 17, 18, 19, 20, 21 or 22.

**8075a-b. Series Instrument Enclosures.**

XP/II/1/BCD/Ta = -40°C to +85°C; DIP/II,III/1/EFG/Ta = -40°C to +85°C; Type 4X, IP66

a = Model AE, AM, SE, SM, TE, TM, WE or WM.

b = Entry configuration 01, 02, 03, 04, 05, 06, 07, 08, 09, 13, 14, 15, 17, 18, or 22.

**8080a-b. Series Instrument Enclosures.**

XP/II/1/BCD/Ta = -40°C to +85°C; DIP/II,III/1/EFG/Ta = -40°C to +85°C; Type 4X, IP66

a = Model AE, AM, SE, SM, TE, TM, WE or WM.

b = Entry configuration 01, 02, 03, 04, 05, 06, 07, 08, 09, 13, 14, 15, 17, 18, or 22.

## Equipment Ratings:

Explosionproof for use in Class I, Division 1, Groups B, C and D; and Dust-Ignitionproof for Class II, Division 1, Groups E, F and G, Class III; hazardous (classified) locations, indoor and outdoor (Type 4X and IP66).

## FM Approved for:

International Metal Engineering Pte Ltd  
Singapore 319261



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3615	2006
Class 3810	2005
ANSI/NEMA 250	2003
ANSI/IEC 60529	2004

Original Project ID: 3028184

Approval Granted: January 26, 2007

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
3034204	March 27, 2009		
3037385	<i>October 27, 2009</i>		

FM Approvals LLC

J. E. Marquedant  
Group Manager, Electrical

*27 October 2009*  
Date