

CERTIFICATE OF COMPLIANCE

Certificate Number R-E85310
Report Reference E85310-19771117
Date 2021-November-04

Issued to: APPLETON GROUP
9377 W HIGGINS RD
ROSEMONT IL 60018 US

**This is to certify that
representative samples of**

OUTLET AND JUNCTION BOXES FOR USE IN
HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical
Equipment for Use in Hazardous (Classified) Locations
UL50E and CSA C22.2 No. 94.2:20, Enclosures for
Electrical Equipment, Environmental considerations
CSA C22.2 No. 25-17, Enclosures for Use in Class II
Groups E, F, and G Hazardous Locations
CSA C22.2 No. 30, Explosion-proof Equipment


Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number R-E85310
Report Reference E85310-19771117
Date 2021-November-04

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Conduit Outlet Boxes for Use in Class I, Division 1, Groups B, C, and D, Class II, Division 1 Groups E, F, and G; Class III Hazardous Locations.

Cat. Nos. GR or GUA, followed by E, C, L, N, T, X, LB, CA, LA, or TA, followed by 50, 75, 100, 125, 150, 200, may be followed by A, M, or MC, may be followed by NC, may be followed by K1DC, K1DCM, and/or NC, may be followed by GR and/or TBx.

Cat. No. GRUSE-100, may be followed by GR and/or TBx.

Cat. No. GRSS or GRSSA, followed by 50, 75, 100, may be followed by GR and/or TBx

Cat. No. GUEB, followed by a number 1 through 13, followed by 50, 75, or 100, may be followed by A, may be followed by N4, may be followed by GR and/or TBx


Cat. Nos. GRTS or GUATS, followed by 150 or 15075, may be followed by A, M, or MC, may be followed by D, G, NS, T1 thru T12.

Conduit sizes 1/2 in. to 2 in. NPT

Outlet Boxes may be marked with the following enclosure type ratings; "Raintight", "TYPE 3", "TYPE 3R", "TYPE 4/4X" and "IP66" when:

1. Cover O-ring is provided
2. If a drain fitting is provided it shall have the same hazardous and environmental ratings as marked on the Outlet Box. When drain fitting not provided drain plug of same environmental rating shall be provided.
3. Outlet boxes, AL Grades, 413 and 712 body and cover painted or unpainted may be marked TYPE 4X.
4. GRTS and GUATS outlet boxes may be marked IP66
5. Type 3R enclosure shall be provided with R/C (EBNV) drain.

Ambient Temperature Range (GRTS/GUATS only); $-40^{\circ}\text{C} \leq T_a \leq +60^{\circ}\text{C}$



Bruce Mahrenholz, Director North American Certification Program

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>